

Tools Required:

Phillips medium screwdriver



**Dimensions**  
A: 10-1/2 "  
B: 3-1/8 "



**Weight:** 4.4 lbs.

**Notice to Installer for 33 636:**

- 1. Mounts directly over a standard recessed 4" octagonal wiring box (by others).
- 2. In conformance with UL Standard 1598, a silicone based sealant must be used between luminaire and mounting surface.

**WARNING:** LEDs are high quality electrical components. Please avoid touching them directly during installation.

**33 636 - Installation:**

- 1. Twist glass counter-clockwise to remove from luminaire housing.
- 2. Feed the luminaire wiring through the luminaire housing.
- 3. Make supply wiring and luminaire wiring connections inside the wiring box:  
MAIN VOLTAGE SUPPLY WIRE TO BLACK LUMINAIRE WIRE  
NEUTRAL (COMMON) SUPPLY WIRE TO WHITE LUMINAIRE WIRE  
GREEN GROUND WIRE TO GREEN LUMINAIRE WIRE


**Dimming (if applicable):**

DIMMING CONTROL WIRE (+) TO POSITIVE DRIVER DIM CONTROL WIRE  
DIMMING CONTROL WIRE (-) TO NEGATIVE DRIVER DIM CONTROL WIRE

- 4. Attach the housing directly to the surface over a 4" standard octagonal wiring box using sufficient hardware (by others).
- 5. To replace glass, rotate clockwise into housing.

**NOTE:** use the mounting detail for mounting hole and wiring box location.

Figure 1



**Relamping/Maintenance**

Twis glass counter-clockwise and remove from housing. Clean glass using only solvent-free cleaners. Replace glass into luminaire housing by rotating clockwise.

**Accessories**

Please refer to the appropriate accessory installation sheet for further instruction when applicable.

**Replacement Parts**

Description	Part No
Lens & Gasket	11277740
LED driver (120-277V)	75983-04
LED module (3000K)	LED-0854/930
LED module (4000K)	LED-0854/940

**Lamp:** 14.2W LED Module

**Product Safety Warnings:**

**THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED. SUITABLE FOR WET LOCATIONS.**

**MIN 90°C SUPPLY CONDUCTORS.**

**CE PRODUIT DOIT ÊTRE INSTALLÉ SELON LE CODE D'INSTALLATION PERTINENT, PAR UNE PERSONNE QUI CONNAÎT BIEN LE PRODUIT ET SON FONCTIONNEMENT AINSI QUE LES RISQUES INHÉRENTS. CONVIENT AUX EMPLACEMENTS MOUILLÉS.**

**LES FILS D'ALIMENTATION 90°C MIN.**

---